



NOTES CONT:

7. MUELLER A-423 OR AMERICAN WATEROUS PACER WB67-250 WITH 5-1/4" VALVE OPENING OR FIRE DEPARTMENT APPROVED EQUAL. RISER SHALL BE 4 FT OR 5 FT AND RISER TYPE SHALL BE SAME AS THE FIRE HYDRANT MANUFACTURER. HYDRANTS MUST BE FACTORY PAINTED TO BE ACCEPTED. ALL HYDRANTS SHALL HAVE TWO 2-1/2" HOSE NOZZLES AND ONE FACTORY INSTALLED INTEGRAL 5" STORZ PUMPER NOZZLE ASSEMBLY.
8. IF PROPOSED HYDRANT LOCATION IS WITHIN PARKWAY OR LANDSCAPE WHERE NO CONCRETE EXISTS, PLACE 36" DIAMETER ROUND OR 36" x 36" SQUARE, 4" THICK REINFORCED CONCRETE SPLASH PAD AS REQUIRED BY THE AHJ. NO FENCES, LANDSCAPE FEATURES, OR OTHER OBSTRUCTIONS SHALL BE ALLOWED WITHIN 3-FEET OF ANY PORTION OF A FIRE HYDRANT. CLEARANCE IS MEASURED FROM ALL OBSTRUCTIONS TO THE NEAREST POINT ON THE FIRE HYDRANT. ANTICIPATED PLANT GROWTH TO BE CONSIDERED IN DESIGN AND INSTALLATION.
9. FIRE HYDRANTS SHALL BE INSPECTED BY AHJ INSPECTOR. INSPECTIONS SHALL BE SCHEDULED A MINIMUM OF TWO BUSINESS DAYS PRIOR AND INSPECTIONS SHALL BE PERFORMED DURING REGULAR BUSINESS HOURS. CONTACT AHJ FIRE PREVENTION BUREAU TO SCHEDULE INSPECTIONS.
10. FIRE HYDRANTS SHALL BE PLACED WITHIN THE RIGHT-OF-WAY OR EASEMENT GRANTED OUTSIDE THE RIGHT-OF-WAY. FIRE HYDRANT PLACED WITHIN PEDESTRIAN WALKWAY AND/OR SIDEWALKS SHALL PROVIDE FOR A MINIMUM OF 4 FT CLEARANCE IN ACCORDANCE WITH PUBLIC RIGHT-OF-WAY ACCESSIBILITY GUIDELINES (PROWAG).
11. AHJ APPROVAL IS REQUIRED FOR HYDRANT LOCATION WHERE NO SIDEWALK EXISTS BEHIND CURB OR WHERE A LANDSCAPE STRIP IS BETWEEN THE CURB AND THE SIDEWALK.
12. FIRE HYDRANTS SHALL BE TESTED BY THE AHJ PRIOR TO COMBUSTIBLES BEING BROUGHT ON SITE.
13. FOR TRENCH EXCAVATION/BACKFILL SPECIFICATIONS SEE DETAIL BELOW. ALL DRAIN ROCK SHALL BE PLACED PRIOR TO INSPECTION AND BACKFILL.

TRENCH EXCAVATION/BACKFILL	
AHJ	DETAIL #
RENO	R-122
SPARKS	S-117
WASHOE COUNTY	W-22

STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION		AHJ	DRAWING No.	
 	<h1>NOTES - FIRE HYDRANT</h1>		RENO	R-301C
			SPARKS	S-301C
			W/C	W-23C
DATE: 1/2020				