

AEROSOLS



OPERATIONAL PERMIT INFORMATION SHEET

This Permit issued and accepted on condition that all provisions of the Codes now adopted, or that may hereafter be adopted, shall be complied with.

- Storage shall be maintained as approved during plans review process. Any change to configuration of or addition to aerosol storage must be approved through building permit plans review process.
- Any change in type of aerosol commodity to be stored must be approved through building permit plans review process.
- The Material Safety Data Sheets for all aerosol products displayed must be kept on the premises at an approved location.
- Cartons shall be identified on at least one side with the product classification level. Aerosol products in cartons which are not identified shall be classified as Level 3.
- Maximum quantities in retail display areas and their adjacent storage areas shall comply with Section 5106 of the 2018 International Fire Code.
- Level 2 and 3 containers shall not be stacked more than 8 feet high.
- Aerosol products located in retail display areas must be removed from combustible cartons.
- Fire separations and fixed fire protection systems shall be maintained.
- Approved fire extinguishers shall be provided and maintained.
- Manufacturing facilities shall comply with NFPA 30B.
- Aerosol facilities must comply with all applicable provisions of the 2018 International Fire Code, particularly Chapter 51, and NFPA 30B. Additional requirements are subject to inspection and review.

The applicant accepts responsibility for the use of this Permit, in full compliance with the terms and conditions above, and additionally hereby to assume, pay and hold the City of Reno harmless for any liability arising out of the Permit. This Permit does not take the place of any license required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

For More Information email:
RFDBusinessLicense@reno.gov