

COMPRESSED GAS



OPERATIONAL PERMIT INFORMATION SHEET

This Permit issued and accepted on condition that all provisions of the Codes now adopted, or that may hereafter be adopted, shall be complied with.

- Containers, cylinders, tanks, and piping systems shall be clearly marked.
- Containers, cylinders, tanks, systems, and valves shall be physically secured, stored in secured areas, protected from extreme temperatures, and all potential sources of ignition.
- Containers, cylinders, tanks, and systems shall be separated from materials and conditions which pose exposure hazards to each other.
- Protective caps, collars, and plugs shall be in place except when the units are in service.
- Combustible wastes shall be kept a minimum of 10 feet from containers, cylinders, tanks, and systems.
- Containers, cylinders, and tanks shall be protected from direct contact with soil or unimproved surfaces.
- Damaged equipment shall be removed from service.
- Equipment shall be stored in an upright position unless otherwise designed.
- Compressed gas systems shall be designed, shall be suitable for the use intended, shall be listed, and shall be approved through the building permits plan review process. Any changes to the system must be approved.
- Compressed gases must comply with the 2018 International Fire Code, particularly Chapter 53. Additional requirements are subject to inspection and review.

The applicant accepts responsibility for the use of this Permit, in full compliance with the terms and conditions above, and additionally hereby to assume, pay and hold the City of Reno harmless for any liability arising out of the Permit. This Permit does not take the place of any license required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

For More Information email:
RFDBusinessLicense@reno.gov