

# High Piled Combustible Storage



## OPERATIONAL PERMIT INFORMATION SHEET

This Permit issued and accepted on condition that all provisions of the Codes now adopted, or that may hereafter be adopted, shall be complied with.

- Any change to configuration of or addition to high piled combustible storage must be approved through the building permit plans review process.
- Any change in type of commodity to be stored must be approved through the building permit plans review process.
- A copy of the evacuation plan must be maintained in an approved location.
- The structural integrity of racks, clearance from ignition sources, aisle accessibility, approved pile dimension and height, and array and flue space clearances must be maintained.
- Required aisle widths shall extend from floor to ceiling, except for approved catwalks.
- Required building separations, fixed fire protection systems, fire access doors, and access to exit doors must be maintained.
- Fire extinguishers shall be provided and maintained.
- High-piled combustible storage facilities must comply with all applicable provisions of the 2018 International Fire Code, particularly Chapter 32, and NFPA 13 and 230. Additional requirements are subject to inspection and review.

The applicant accepts responsibility for the use of this Permit, in full compliance with the terms and conditions above, and additionally hereby to assume, pay and hold the City of Reno harmless for any liability arising out of the Permit. This Permit does not take the place of any license required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

For More Information email:  
RFDBusinessLicense@reno.gov