

# LIQUID OR GAS FUELED VEHICLES OR EQUIPMENT IN PLACES OF ASSEMBLY



## OPERATIONAL PERMIT INFORMATION SHEET

This Permit issued and accepted on condition that all provisions of the Codes now adopted, or that may hereafter be adopted, shall be complied with.

- Location shall not obstruct free and immediate access to egress.
- Batteries must be disconnected.
- Fuel in fuel tanks must not exceed one-quarter tank or 5 gallons, whichever is least.
- Fuel systems shall be inspected for leaks.
- Fuel tanks and fill openings must be closed and sealed to prevent escape of vapors.
- Neither fueling nor defueling may be done within the structure.
- CNG or LPG vehicles shall close the quarter turn shutoff or other shutoff valve and run the engine until it stops, keep the valves shut, and disconnect the hot lead of the battery.
- Liquid or Gas Fueled Vehicles or Equipment in Assemblies must comply with all applicable provisions of the 2018 International Fire Code. Additional requirements are subject to inspection and review

The applicant accepts responsibility for the use of this Permit, in full compliance with the terms and conditions above, and additionally hereby to assume, pay and hold the City of Reno harmless for any liability arising out of the Permit. This Permit does not take the place of any license required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

For More Information email:  
RFDBusinessLicense@reno.gov