

# LP-GAS



## OPERATIONAL PERMIT INFORMATION SHEET

This Permit issued and accepted on condition that all provisions of the Codes now adopted, or that may hereafter be adopted, shall be complied with.

- LP-Gas equipment shall be installed and maintained in accordance with NFPA 54, NFPA 58, and Chapter 61 of the 2018 International Fire Code.
- Fixed fire protection systems shall be maintained in an operative condition.
- Approved fire extinguishers shall be provided and maintained.
- Portable LP-gas containers shall not be used in buildings unless as otherwise approved.
- Storage and location of containers shall be as specified in IFC Chapter 57 and shall be maintained in an approved manner.
- Safety devices on LP-gas containers, equipment, and systems shall not be tampered with or made ineffective.
- Vegetation and other combustible material shall be kept at a minimum of 10 feet from LP-gas tanks or containers.
- Containers shall be protected from vehicles in an approved manner.
- Empty containers that have been in service shall be considered as full containers for the purpose of determining maximum allowable storage quantities.
- Smoking shall be prohibited within 25 feet of a point of transfer while filling operations are in progress. Signs shall be posted.
- Dispensing of LP-gas shall be performed by a qualified attendant.
- LP-gas tank vehicles shall not be left unattended in other than approved areas.
- Each facility shall have written operating and emergency procedures which all employees must be familiar with.
- LP-Gas facilities must comply with all applicable provisions of the 2018 International Fire Code, particularly Chapter 61, NFPA 54, and NFPA 58. Additional requirements are subject to inspection and review.

The applicant accepts responsibility for the use of this Permit, in full compliance with the terms and conditions above, and additionally hereby to assume, pay and hold the City of Reno harmless for any liability arising out of the Permit. This Permit does not take the place of any license required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

For More Information email:  
RFDBusinessLicense@reno.gov

# LP-GAS

For More Information email:  
[RFDBusinessLicense@reno.gov](mailto:RFDBusinessLicense@reno.gov)