

MISCELLANEOUS COMBUSTIBLE STORAGE



OPERATIONAL PERMIT INFORMATION SHEET

This Permit issued and accepted on condition that all provisions of the Codes now adopted, or that may hereafter be adopted, shall be complied with.

- Storage shall be orderly and shall be separated from heat sources.
- Storage shall be maintained 2 feet or more below the ceiling in non-sprinklered buildings.
- Storage shall be maintained 18 inches or more below sprinkler head deflectors in sprinklered areas of buildings.
- Combustibles shall not be stored in boiler, mechanical, or electrical equipment rooms or in exits or exit enclosures.
- Attics, under-floor, and concealed spaces used for storage shall either be sprinklered or protected on the storage side by one hour construction, and any openings shall be protected in an approved manner.
- Storage shall not be placed on exposed joists.
- Outside storage shall not be located within 10 feet of a property line.
- In a sprinklered building, storage shall not be placed under non-sprinklered eaves.
- Storage in the open shall not exceed 10 feet in height.
- Miscellaneous Combustible Storage must comply with all applicable provisions of the 2018 International Fire Code. Additional requirements are subject to inspection and review.

The applicant accepts responsibility for the use of this Permit, in full compliance with the terms and conditions above, and additionally hereby to assume, pay and hold the City of Reno harmless for any liability arising out of the Permit. This Permit does not take the place of any license required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

For More Information email:
RFDBusinessLicense@reno.gov

**MISCELLANEOUS
COMBUSTIBLE
STORAGE**

For More Information email:
RFDBusinessLicense@reno.gov