

# REPAIR GARAGES



## OPERATIONAL PERMIT INFORMATION SHEET

This Permit issued and accepted on condition that all provisions of the Codes now adopted, or that may hereafter be adopted, shall be complied with.

- Cleaning of parts shall be conducted in approved parts cleaning machines only.
- Sources of ignition shall not be located within 18 inches of the floor.
- Smoking shall be allowed in designated areas only.
- Pits and below-grade areas shall be maintained as approved during the plans review process.
- Fuel shutoff valves shall be closed prior to repairing any portion of the vehicle fuel system.
- When the fuel system has been damaged, it shall be evaluated for system integrity and leakage prior to being brought in the garage.
- Repair garages must comply with applicable provisions of the 2018 International Fire Code, and NFPA 30A. Additional requirements are subject to inspection and review.

The applicant accepts responsibility for the use of this Permit, in full compliance with the terms and conditions above, and additionally hereby to assume, pay and hold the City of Reno harmless for any liability arising out of the Permit. This Permit does not take the place of any license required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.